



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT

1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP
Director

Dale J. Fletcher, CBO
Assistant Director

December 21, 2017

Steve Bortolazzo
Meek's Anderson Water System
6781 Eastside Road
Anderson, CA 96007

CITATION NO. 01_75_17C_013_4500337_52 FOR NONCOMPLIANCE WITH SECTION 116555 OF THE CALIFORNIA HEALTH AND SAFETY CODE AND SECTIONS 64675 AND 64690 OF THE CALIFORNIA CODE OF REGULATIONS FOR LEAD AND COPPER MONITORING AND REPORTING

The California Health and Safety Code (CHSC), Division 104, Part 12, Chapter 4, Article 9, Section 116650, authorizes the issuance of citations for failure to comply with requirements of Chapter 4 (California Drinking Water Act), or any regulation, standard, permit, or order issued thereunder. The Shasta County Environmental Health Division (SCEHD) hereby issues a citation to the Meek's Anderson Water System (Water System) for failure to comply with Sections 64675 and 64690, Title 22, of the California Code of Regulations (CCR) and Section 116555 of the CHSC.

VIOLATIONS

The SCEHD hereby issues a Citation to the Water System for failure to comply with Section 116555(a) of the CHSC and Title 22, CCR. Specifically, the Water System failed to comply with the primary standard for lead and copper monitoring for the Summer 2017 monitoring period.

The Water System operates under a domestic water supply permit issued by SCEHD in February 2015. The Water System is classified as a non-transient/non-community public water system serving approximately 40 people through three service connections.

DETERMINATIONS

The SCEHD has determined that the Water System violated 64675.5(a)(1) and Section 64690.1, Title 22, of the CCR, in that the Water System failed to collect and report correctly for the Summer 2017 reporting period.

DIRECTIVES

The Water System is hereby directed to take the following actions:

1. Comply with Section 64675.5, Title 22, of the CCR in all future monitoring periods.

☐ Suite 101
AIR QUALITY MANAGEMENT DISTRICT
530 225-5674
Fax 530 225-5237

☐ Suite 102
BUILDING DIVISION
530 225-5761
Fax 530 245-6468

☐ Suite 103
PLANNING DIVISION
530 225-5532
Fax 530 245-6468

☒ Suite 201
ENVIRONMENTAL HEALTH DIVISION
530 225-5787
Fax 530 225-5413

☐ Suite 200
ADMINISTRATION & COMMUNITY EDUCATION
530 225-5789
Fax 530 225-5807

December 21, 2017

2. Conduct lead and copper monitoring from customer's taps during the time period of June, July, August, or September 2018. Samples shall be collected in accordance with the Lead and Copper Rule sampling procedures per Title 22, Section 64677. The analytical results must be reported to the SCEHD by the 10th day of the month following the month in which the analysis was completed.
3. The Water System shall provide public notification (by inclusion in the 2017 Consumer Confidence Report) of the failure to sample for lead and copper, as required by the Lead and Copper regulations.

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of CHSC, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), or any regulation, permit, standard or order issued or adopted thereunder.

CIVIL PENALTY

Section 116650(e) of the California Health and Safety Code authorizes the SCEHD to issue citations with assessment of administrative penalties to a public water system for violations or continued violations of the requirements allowed for any permit, regulation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. Since this is the first citation issued for Lead and Copper monitoring failure, no assessed civil penalty will be required for this monitoring violation.


Failure to comply with any provision of this citation will result in a citation that may include an assessed civil penalty of up to two hundred dollars (\$200) per day for each day the violation continues beyond the date specified for correction in the citation.

PARTIES BOUND

This Citation shall apply to and be binding upon the Water System, its officers, directors, agents, employees, contractors, successors, and assignees.


SEVERABILITY

The directives of this Citation are severable, and the Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any other provision.



Renita Salas, R.E.H.S.

Shasta County Environmental Health Division



Date